



中国认可
国际互认
检测
TESTING
CNAS L0690

TEST REPORT

Report No.: WT2023B01A04733

Shanghai Huayuan New Composite Materials
Entrusted by: CTCC Co.,Ltd

Sample Name: Multi-Layer-Aluminum Honeycomb Panel

Test Type: Entrusted test

China Testing & Certification International Group Co.,Ltd.
National Research Center of Testing Techniques for Building
Materials



WT2023B01A04733

Notice

1. This test report is invalid without the seal or cross-page seal.
 2. This test report is invalid without the signatures of the related persons.
 3. This test report is invalid if erased, altered or copied partially.
 4. Any doubt should inform us within 15 days after receiving the test report.
 5. The entrustment test samples and relevant information are provided by entrusted body, the laboratory does not responsible for authenticity. The results shown in this report refer only to the samples tested.
 6. This test report is printed on anti-counterfeiting paper. Copies made from original should have grid shadings. The numbers on the back of the data sheet are random and do not related with the report.
-

Laboratory Contact information:

Address: No.1 Guanzhuang Dongli, Chaoyang District, Beijing, 100024, P.R. China.

Web: www.ctc.ac.cn

Customer online service platform: <http://www.ctc-online.cn>

Telephone of service reception: 400-010-0010, +86-10-51167681

Email of service reception: ywjd@ctc.ac.cn

Telephone of genuine enquiries and complaints: 400-010-0010, +86-10-51167679

China Testing & Certification International Group Co.,Ltd.
National Research Center of Testing Techniques for Building
Materials

Test Report

Report No.: WT2023B01A04733

Page 1 of 2

Sample Name	Multi-Layer-Aluminum Honeycomb Panel	Test Type	Entrusted test
Entrusted by	Shanghai Huayuan New Composite Materials Co.,Ltd	Brand	ALUCOBEST
Manufacture	Shanghai Huayuan New Composite Materials Co.,Ltd	Sample State	Meet the requirements of testing
Receiving Date	August 23, 2023	Quantity of sample	1m ²
Production Date	_____	Model/Size	1220×2750 18-0.3/0.3-4×0.05
Test Method	The method for the test items are detailed in the data page.	Test Date	August 25-September 12, 2023
Test Item	Formaldehyde emission (climate chamber method)		
Test Result	*The test data is detailed in the data page.* Date of issue: 2023-09-15 (Seal)		
Remarks:(Provided by Client) Multi-Layer-Aluminum Honeycomb Panel : Total thickness 18mm, face aluminum 0.3mm, bottom aluminum 0.3mm, honeycomb core 4×4×0.05mm。			

Approved by: 徐升平 Checked by: 刘宾华 Compiled by: 王桂芳

Address: No.1 Guanzhuang Dongli ,Chaoyang District, Beijing, China
Tel: 00-86-10-51167681


P.C.: 100024

China Testing & Certification International Group Co.,Ltd.
National Research Center of Testing Techniques for Building
Materials

Test Report

Report No.: WT2023B01A04733

Page 2 of 2

No.	Test Item	Test Result	Test method
1	Formaldehyde emission (climate chamber method) / (mg/m ³)	Not Detected (95h)	GB/T 17657-2022 4.60
(Blank)			
			
Remarks: 1. Test location: Yongshun. 2. Not Detected: Formaldehyde emission < 0.005mg/m ³ .			

End of the Report

Address: No.1 Guanzhuang Dongli ,Chaoyang District, Beijing, China
Tel: 00-86-10-51167681

P.C.: 100024

8073767